

CHAPTER 14

EXTERIOR WALLS

[Corrections to IBC 2003. Only selected sections needing editing are given].

1403.6 Flood resistance. For buildings in flood hazard areas as established in Section 1612 ~~1612.3~~, exterior walls extending below the design flood elevation shall be resistant to water damage. Wood shall be pressure-preservative treated in accordance with AWPA C1, C2, C3, C4, C9, C15, C18, C22, C23, C24, C28, P1, P2 and P3, or decay-resistant heartwood of redwood, black locust or cedar.

1403.7 Flood resistance for high-velocity wave action areas. For buildings in flood hazard areas subject to high-velocity wave action as established in Section 1612 ~~1612.3~~, electrical, mechanical and plumbing system components shall not be mounted on or penetrate through exterior walls that are designed to break away under flood loads.

1405.5.2 Seismic requirements. Anchored masonry veneer located in Seismic Design Categories C and D ~~Category C, D, E or F~~ shall conform to the requirements of Section 6.2.2.10 of ACI 530/ASCE 5/TMS 402. Anchored masonry veneer located in Seismic Design Category B shall conform to the requirements for Category C of Section 6.2.2.10 of ACI 530/ASCE 5/TMS 402.